



Office of the
Executive Engineer (E)
P & C Building,
New Kandla, Kachchh
Tel : 02836 270209
Fax: 02836 270184
www.kandlaport.gov.in

No.: EL/AC/EOI/

Date: 29/11/2023

EXPRESSION OF INTEREST

(This Notice is issued only to elicit Expression of Interest from the parties interested in the work and does not constitute any binding commitment from the Deendayal Port Trust to proceed with the work or invite any or all the parties in the subsequent bidding process. The Open Tenders will be issued subsequently)

To,

_____.

Sub: EOI for "Overhead Water Tank Level Control System initially for the Bungalows/Quarters of Chairman, Dy. Chairman & HoDs at the Port Colony, Goppalpuri"

Sir,

You are requested to submit the Expression of Interest for "Overhead Water Tank Level Control System initially for the Bungalows/Quarters of Chairman, Dy. Chairman & HoDs at the Port Colony, Goppalpuri"

The Expression of Interest should reach this office on or before 15/12/2023 or soft copy of EOI also acceptable through e-mail id. xenedpa@gmail.com & deepak.hazra@deendayalport.gov.in

Yours faithfully,

Sd/-
Executive Engineer (E)
Deendayal Port Trust

ELECTRICAL DIVISION

Name of Work: Design, Supply, Installation, Testing, Commissioning of electronics based automatic level control system for overhead/underground tanks at Port Colony, Gopalpuri

Schedule-B

S/N	Description	Qty	Unit	Rate		Amount
				In Fig	In Words	
1	Design, supply, installation, testing & commissioning of electronics based automatic level control system for overhead tank with overhead & underground level sensors/switches, cables, connectors, logic control, other accessories to be integrated with the existing motor, complete in all respects with labour.	9	Complete Job			
Total Amount Rs.						

(In Words: Rs. _____)

Note: The rates should be inclusive of all taxes, duties, fees, cess etc. and all incidental charges, but exclusive of GST.

Handwritten: 28/11/23
Executive Engineer (Electrical)
Deendayal Port Authority

Terms and Conditions

- (1) The work shall be completed within 2 months from the date of issue of work order.
- (2) The work shall be guaranteed for one year and during the Guarantee period all the faults shall be attended by the contractor.
- (3) The system shall have protected against over/under voltages, surges etc. and shall operate on 230 V, 50 Hz, AC Supply.
- (4) The earthing system shall be arranged by Deendayal Port Authority. However, the DC grounding will be in the scope of the contractor.
- (5) The approval of all the materials/ components shall be obtained from Deendayal Port Authority.
- (6) The rates shall be inclusive of all taxes, duties, incidental charges etc. but excluding GST only.
- (7) The rates in words will be considered if there is any mismatch in figures and words.


Executive Engineer (Electrical)
Deendayal Port Authority