

DEENDAYAL PORT AUTHORITY
ENGINEERING DEPARTMENT
T.D.DIVISION

CORRIGENDUM - III

TENDER NO. 01-TD/2026 (265031)

Name of Work:-“Beautification of Gopalpuri Colony (Widening of the entry gate and enhancement of surrounding approaches).”

| | |
|---|------------------------|
| Last Date & Time for Receipt of Online Bids | 27/03/2026 @16:00 Hrs. |
| TIME & DATE OF OPENING OF BIDS : | 27/03/2026 @16:05 Hrs. |

➤ **Electrical Part**

Technical Specification No. 19 may be read as "Supply, Installation, Testing and Commissioning of 500 kVA 11/0.43 kV Outdoor Type Compact Substation with HT Panel, Transformer, LT Panel, Protection and Metering Device, etc. and other relevant accessories in a suitable enclosure with IP54

Further, wherever 250 KVA dry type transformer is mentioned in Technical Specification No. 19, the same shall be read as 500 KVA Dry Type Transformer.

Other Terms and Conditions of the tender will remain unaltered.


Executive Engineer (TD)
Deendayal Port Authority